

NOTE:

1. METAL EDGE SHOULD BE DESIGNED FOR WIND RESISTANCE IN ACCORDANCE WITH THE APPLICABLE EDITION OF ASCE 7 AND TESTED FOR CAPACITY IN ACCORDANCE WITH THE TEST METHODS IN THE APPLICABLE EDITION OF ANSI/SPRI ES-1.
2. FOR STEEL ROOF DECKS: FILL STEEL DECK FLUTES WITH CLOSED CELL SPRAY FOAM INSULATION PRIOR TO THE INSTALLATION OF ABOVE DECK INSULATION A MINIMUM OF 12 INCHES (305 mm) FROM FACE OF WALL.



OUTTED WITH COATED METAL DOOF FDOE					LEGEND
GUTTER WITH COATED METAL ROOF EDGE					HEAT-WELDED
					EVERGUARD® WATER BLOCK
DRAWING #		THIS DETAIL APPLIES TO:	ISSUE / REVISION DATE	SCALE	
011D		ADHERED SYSTEMS	7/00/0000		EVERGUARD® BONDING ADHESIVE
		MECHANICALLY ATTACHED SYSTEMS RHINOBOND® SYSTEMS	7/28/2023	N.T.S.	CLOSED CELL FOAM INSULATION