



NOTE:

- 1. A FIELD WELD CANNOT PASS WITHIN 9" (227 mm) OF THE CLAMPING, OR WITHIN THE DRAIN SUMP ITSELF.
- 2. MEMBRANE MUST EXTEND MINIMUM 1" (25.4 mm) BEYOND THE BOLT HOLES. THE CLAMPING RING BOLTS MUST PENETRATE THE MEMBRANE.
- 3. TAPERED INSULATION TO CREATE A ROOF SUMP MINIMUM 36" (0.914 m) x 36" (0.914 m) IN SIZE. (IF APPLICABLE).
- 4. USE ONE FULL TUBE OF FLEXSEAL CAULK GRADE SEALANT OR EVERGUARD® WATER BLOCK PER DRAIN.
- 5. ASPHALT OR STONE PAVER MUST STOP AT DRAIN TAPER.



DRAIN -STANDARD ROOF DRAIN FLASHING DETAIL

DRAWING #	THIS DETAIL APPLIES TO:	ISSUE / REVISION DATE	SCALE
513A	ALL SYSTEMS	4/30/21	N.T.S.

LEGEND

 EVERGUARD® WATER-BLOCK OR FLEXSEAL™ CAULK GRADE SEALANT